

Testing. Advising. Assuring.

WF Report No. 193968
Page 1 of 2
3rd June 2010

Culimeta Saveguard Ltd

Tame Valley Mill
Wainwright Street
Dukinfield
Cheshire
SK16 5NB

Review of Assessment Report Referenced WFRC No. C129848

1 Introduction

The assessment referenced WFRC No C129848 provided an appraisal relating to the expected fire resistance performance of 'Firehalt 60/30' insulated fabric fire barriers. This appraisal also considers various modifications to the tested construction.

The report concluded that the fabric barriers would be expected to satisfy the integrity and insulation performance requirements of BS 476: Part 22: 1987, for periods up to 60 and 30 minutes respectively, when exposed to the heating conditions specified in that standard.

2 Confirmation of Specification

It has been confirmed by Culimeta Saveguard Ltd that there have been no changes to the material specifications and methods of construction considered in the original appraisal referenced WFRC No C129848.

3 Conclusions

The data used for the original appraisal has been re-examined and found to be satisfactory.

The procedures adopted for the original assessment have been re-examined and are similar to those currently in use.

Therefore, with respect to the assessment of performance given in WFRC No. C129848, the contents should remain valid until the 1st July 2015.

4 Validity

This review is based on information used to formulate the original assessment. No other information or data has been provided by Culimeta Saveguard Ltd which could affect this review.

The original appraisal report was performed in accordance with the principles of the UK Fire Test Study Group Resolution 64A: 1993, which has since been superseded by Resolution 82: 2001. This review has therefore also been conducted using the principles of Resolution 82: 2001.

Performed by:



A Kearns
Technical Manager
Exova warringtonfire

Reviewed By:



C Johnson
Principal Certification Engineer
Exova warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.