

Testing. Advising. Assuring.

WF Report No. 193971
Page 1 of 2
3rd June 2010

Culimeta Saveguard Ltd

Tame Valley Mill
Wainwright Street
Dukinfield
Cheshire
SK16 5NB

Review of Test Report Referenced WARRES No. 106496

1 Introduction

The report referenced WARRES No. 106496 relates to a fire resistance test performed generally in accordance with BS 476: Part 22: 1987, Clause 5, on a specimen of an insulated fabric barrier.

The specimen had overall dimensions of 3035 mm high by 3050 mm wide and incorporated a nominally 7.1 mm thick fabric referenced 'FireHalt Gold'. The specimen was retained by steel angles at the perimeter and included three vertical joints.

The specimen satisfied the performance requirements specified in Clause 5 of BS 476: Part 22: 1987 for insulated specimens, for the following periods:

Integrity	:	132 minutes
Insulation	:	38 minutes

The test was discontinued after a period of 132 minutes.

2 Confirmation of Specification

It has been confirmed by Culimeta Saveguard Ltd that there have been no changes to the specification or the construction given in the original report referenced WARRES No. 106496.

3 Conclusions

At present there are no additional resolutions adopted by the Fire Test Study Group since the original test was performed which would affect the manner in which the test would be conducted or the interpretation of the test results.

The procedures adopted for the original test have been re-examined and are similar to those currently in use.

Therefore, with respect to the fire resistance test report referenced WARRES No. 106496 its contents should remain valid until 1st July 2015.

4 Validity

This review is based on information used to formulate the original test report. No other information or data has been submitted by Culimeta Saveguard Ltd, which could affect this review.

Performed by:



A Kearns
Technical Manager
Exova warringtonfire

Reviewed By:



C Johnson
Principal Certification Engineer
Exova warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.